

Enhancements to Single-Loop PID Feedback Control

PART

IV

As we have seen, single-loop PID feedback control often provides good control performance and always yields zero steady-state offset for steplike inputs. The controller is easy to use, because the PID control algorithm can be applied on nearly all processes without alteration. The performance is very good, considering the little information required for design and tuning. As might be expected, the simplicity of the PID controller, while reducing engineering effort and computer calculations, results in control performance that is not always the best possible. The key advantages and disadvantages of single-loop feedback control are summarized in Table IV.1. The methods in Part IV are designed to partially overcome these disadvantages.

The best approach for improving control performance is to eliminate or reduce the disturbances by improving the operation of upstream processes. The next best solution is to eliminate the difficult factors from the feedback dynamic responses by changing the process design. For example, the dead time could be reduced by relocating sensors or eliminating sample systems by placing the sensor *in situ*. If the dead time could be reduced sufficiently, much improved control performance could be achieved. However, changing the process design is not always possible or the best economic decision.

We assume here that all reasonable process modifications have been made and that further enhancements are to be achieved through control modifications. To improve the feedback performance, the controller design must be changed in a manner that takes advantage of additional knowledge about the process dynamics or control objectives through one or more of the following steps:

TABLE IV.1**Summary of single-loop feedback control**

Advantages	Disadvantages
Achieves zero steady-state offset for all step-like inputs	Process output must be upset before feedback action begins.
Uses only one measurement	Feedback control performance can be poor for some combinations of disturbance frequencies and feedback dynamics.
Algorithm and tuning rules available	Poor feedback can cause instability. PID does not provide the best possible control for all processes.

- Use additional measures of process outputs.
- Use additional measurements of the process inputs.
- Use explicit modelling in the control calculation.
- Modify the PID algorithm and tuning to match the control objective.

To achieve enhancements the engineer requires additional process insight, which is developed through increased engineering analysis and effort. The additional effort can be richly rewarded, because the enhancements can substantially improve control performance, reducing the integral errors and maximum deviations by more than a factor of ten, in some situations. The success of the enhancement depends on the quality of the engineering analysis—that is, the accuracy of the process insight and the application of the design principles. It is important to remember that regardless of the complexity of the enhancements, feedback control from the controlled variable should always be retained (when the sensor exists) so that zero steady-state offset is achieved.

Several control enhancements are presented in this part of the book. They were chosen based on the following criteria:

- *Reinforce principles.* Each of these enhancements partially overcomes one or more of the causes for poor control performance. Thus, we have the opportunity to reconsider these process-related limitations as we learn how an enhancement improves performance. This perspective is important because the enhancements are designed based on sound control theory and are not a collection of “ad hoc tricks.”
- *Demonstrate practice.* The enhancements are some of the most frequently applied designs in the process industries and can be implemented in commercial control equipment at low cost.
- *Apply process insight.* The proper use of the enhancements requires sound understanding of dynamics and operating goals of the process. Thus, this part

strengthens our understanding of how the process equipment and operating conditions influence designs to achieve specified control performance.

Each enhancement is briefly summarized in Table IV.2; the reader may find it helpful to refer to this table after covering each chapter in this part.

The single-loop enhancements covered in this part are used widely in process control. They become especially important when designing control strategies for complex units with many controlled variables, sensors, and final control elements. Therefore, it is essential that the student master these enhancements before progressing to the more advanced, multivariable design topics.

TABLE IV.2
Summary of single-loop control enhancements

Enhancement	Key issue	New input measurement	New output measurement	Process modelling	Standard or modified PID	New control algorithm
Cascade	Feedback dynamics		X		X	
Feedforward	Feedback dynamics	X				X
Nonlinear processes	Changing process dynamics	X		X	X	
Inferential	Lack of online sensor		X	X	X	
Level	Different control objective				X	
Predictive control	Complex feedback dynamics			X		X